

UJVN Ltd., "UJJWAL" Maharani Bagh, GMS Road, Dehradun - 248006
Generation Target for 2012-13 as Approved by CEA (in MU)

Power Station	Chibro	Khodri	Dhakrani	Dhalipur	Kulhal	Tiloth	MB Stage-II	Chilla	Ramganga	Khatima	SHPs	Total
Capacity (MW)	240	120	33.75	51	30	90	304	144	198	41.4	58.1	1310.25
April'12	47	22	9	12	9	41	73	59	30	10	10.45	322.45
May'12	63	30	11	17	11	62	148	71	24	15	10.77	462.77
June'12	77	36	14	21	13	58	177	75	21	16	11.87	519.87
July'12	113	50	19	29	17	41	173	85	0	17	12.95	556.95
August'12	109	49	19	27	17	9	119	84	0	17	12.44	462.44
September'12	104	46	18	27	18	44	160	78	0	16	15.20	526.20
October'12	77	35	15	22	16	59	139	77	5	14	10.38	469.38
November'12	44	21	9	14	11	42	85	57	7	10	13.58	313.58
December'12	34	17	7	10	8	33	64	51	35	11	13.48	283.48
January'13	31	15	6	9	8	27	54	53	59	11	12.88	285.88
February'13	27	13	5	8	7	24	46	52	50	9	11.61	252.61
March'13	36	16	7	10	9	31	62	57	47	9	13.06	297.06
Total	762	350	139	206	144	471	1300	799	278	155	148.67	4752.67

Note :

1. Target of all Power Stations except SHPs have been approved by CEA.
2. Target of 9.7 MU for KG-1 SHP is included in the target of SHPs (COD of KG-1 - 10.09.2012)