


Monthly Outage Of various HEPs for the month of April 2016															MIS			
															UJVN Limited		Date	
Outage in HEPs in Hrs																		
Name of HEPs	Reserve Outage					Planned Outage					Forced Outage					Remark on Outage		
	Unit 1	Unit 2	Unit 3	Unit 4	Total	Unit 1	Unit 2	Unit 3	Unit 4	Total	Unit 1	Unit 2	Unit 3	Unit 4	Total			
Chibro	426.91	615.41	247.25	0.0	1289.57	0.0	0.0	0.0	744.0	744.0	0.0	0.0	0.0	0.0	0.0	-		
Khodri	431.593	572.83	366.83	344.75	1716	99.1	79.8	91.3	0.0	270.2	0.0	0.0	0.0	0.0	0.0	-		
Dhakrani	506.45	22.35	101.5	-	630.3	0	0	611.67	-	611.7	0.0	0.0	0.0	-	0	-		
Dhalipur	514.67	4.86	0.0	-	519.53	0.0	0.0	720	-	720.0	0.0	0.0	0.0	-	0	-		
Kulhal	249.25	407.57	440.45	-	1097.27	0.0	0.0	0.0	-	0.0	0	0	57.45	-	57.45	UAT problem in Unit 3		
Tiloth	144.4	68.167	305.91	-	518.487	485.9	24.0	125.9	-	635.8	0	0	0	-	0	-		
Dharasu	95.4	363.33	208.71	170.28	837.753	288.0	0.0	335.5	82.3	705.8	19.6	0.0	23.8	9.5	52.84	T/F bushing oil leakage		
Chilla	110.5	69.4	238.41	211.8	630.02	452.9	0.0	0.0	0.0	452.9	0.0	0.0	0	0.5	0.5	Excitation problem in Unit 4		
Ramganga	673.3	590	720	-	1983.25	0.0	0.0	0.0	-	0.0	0.0	0.0	0.0	-	0			
Khatima	62.88	10.31	0	-	73.19	0.0	659.9	720.0	-	1379.9	4.81	0.0	0.0	-	4.81	Aux supply fail, Bus bar problem		
Pathri	15.35	60.75	9.21	-	85.31	0.0	0.0	0.0	-	0.0	0.0	0.0	0.33	-	0.33	Shaft seal pressure low		
Mohd. Pur	41.567	177.3	32.55	-	251.417	0.0	0.0	0.0	-	0.0	47.8	3.7	4.3	-	55.693	PF control problem, problem in TGB		
Galogi	720	671	0.0	57.33	1448.33	0.0	0.0	720	0	720.0	0.0	0.0	0.0	0.0	0	-		