

	Monthly Outage Of various HEPs for the month of February 2016															UJVN Limited
	Outage in HEPs in Hrs															
Name of HEPs	Reserve Outage					Forced Outage					Planned Outage					
	Unit 1	Unit 2	Unit 3	Unit 4	Total	Unit 1	Unit 2	Unit 3	Unit 4	Total	Unit 1	Unit 2	Unit 3	Unit 4	Total	
Chibro	173.66	495.66	490.167	320	1479.49	0.0	0.0	0.0	0.0	0	0	89.16	0	324.17	413.327	
Khodri	450.5	529.25	237.67	403.58	1621	0.0	0.0	0.0	0.0	0	0	151.6	324	141.25	616.85	
Dhakrani	96.01	0.0	610.75	-	706.76	0.41	0	0	-	0.41	0	696	0	-	696	
Dhalipur	395.16	243.16	0	-	638.32	0	0	0	-	0	0	61.6	696	-	757.6	
Kulhal	509.25	163.42	23.33	-	695.996	0	0	0	-	0	0	179.16	370.16	-	549.32	
Tiloth	0.0	180.56	532.467	-	713.027	0	0	0	-	0	696	0	0	-	696	
Dharasu	361.58	434.6	76.46	342.55	1215.19	19.65	9.5	4.13	0.0	33.28	255	0.0	564.3	60.58	879.88	
Chilla	13	0.0	112.67	0.0	125.67	0.0	0.0	2.91	0.0	2.91	0.0	0.0	0	696	696	
Ramganga	0	0	0	-	0	0	0	0	-	0	0	0	0	-	0	
Khatima	2.68	0	0	-	2.68	4.2	0	0	-	4.2	0	696	696	-	1392	
Pathri	8.8	9.43	21.51	-	39.74	1	0.6	0.33	-	1.93	0	0	0	-	0	
Mohd. Pur	1.06	19.56	10.46	-	31.08	0.0	0.0	0.0	-	0.0	0.0	0.0	0.0	-	0	
Galogi	696	129.5	0	60.5	886	0	0	0	0	0	0	491.5	696	0	1187.5	

MIS
Date
Remark on Outage
-
-
Magnetic valve operated in Unit 1
-
Isolator Fault Bus A
Problem in Intake gate
-
Cooling system problem
Cooling system problem
-
-