


Monthly Outage Of various HEPs for the month of May 2016															MIS	
															UJVN Limited	Date
Outage in HEPs in Hrs																
Name of HEPs	Reserve Outage					Planned Outage					Forced Outage					Remark on Outage
	Unit 1	Unit 2	Unit 3	Unit 4	Total	Unit 1	Unit 2	Unit 3	Unit 4	Total	Unit 1	Unit 2	Unit 3	Unit 4	Total	
Chibro	364.33	419.23	106.65	0.0	890.21	0.0	0.0	0.0	744.0	744.0	0.0	10.1	0.0	0.0	10.1	-
Khodri	224.1	49.75	324.73	353.83	952.414	0.0	684.5	0.0	0.0	684.5	0.0	0.0	0.0	0.0	0.0	-
Dhakrani	281.01	17.68	719.2	-	1017.89	0.0	0.0	0.0	-	0.0	0.0	0.0	0.0	-	0	-
Dhalipur	368.83	67.65	140.1	-	576.56	0.0	0.0	527.75	-	527.8	0.4	0.0	0.0	-	0.41	FCB problem in Unit 1
Kulhal	330.616	356.2	270.03	-	956.846	0.0	0.0	0.0	-	0.0	0.0	0.0	24	-	24	AVR problem
Tiloth	28.7	0.0	15.2	-	43.87	24.0	24.0	20.8	-	68.8	2.91	720	1.16	-	724.07	Grid
Dharasu	152.8	32.06	24.6	45.03	254.506	0.2	0.0	0.0	0.0	0.2	16.6	350.5	4.2	4.93	376.19	Runner Replacement
Chilla	63.8	21.7	229.68	482.0	797.12	0.0	0.0	24.0	24.0	48.0	3.2	2.3	3.68	3.21	12.3	Grid
Ramganga	519.9	498.66	744	-	1762.57	0.0	0.0	0.0	-	0.0	0.0	0.0	0.0	-	0	
Khatima	82.03	115.23	0	-	197.263	0.0	0.0	744.0	-	744.0	24.01	49.4	0.0	-	73.393	AVR fault, Shear pin fault
Pathri	64.383	143.25	30.867	-	238.5	0.0	0.0	0.0	-	0.0	0.0	0.0	0	-	0	
Mohd. Pur	55.28	187.67	118.534	-	361.484	0.0	0.0	0.0	-	0.0	0.0	0.0	0.0	-	0	
Galogi	744	672.08	0.0	86.91	1502.99	0.0	0.0	744	0	744.0	0.0	0.0	0.0	0.0	0	-