

Monthly Generation Loss (MU)																					MIS	
																					Date	
Generation Loss for the Month of April 2016																						
Name of HEP	B/D of Equipment					System Condition					Flushing & Choking					Unusual & Other Reason					Total Loss	Remark
	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total		
Chibro	0	0	0	0	0	0	0	0.0525	0	0.0525	0	0	0	0	0	0	0	0	0	0	0.0525	Grid
Khodri	0	0	0	0	0	0	0	0.023	0	0.023	0	0	0	0	0	0	0	0	0	0	0.023	Grid
Dhakrani	0	0	0	-	0	0.0121	0.03802	0	0	0.05015	0	0	0	-	0	0	0	0	-	0	0.05015	Grid
Dhalipur	0	0	0	-	0	0.009	0.0175	0	-	0.02651	0	0	0	-	0	0	0	0	-	0	0.02651	Grid
Kulhal	0	0	0	-	0	0.0033	0.0123	0	-	0.01563	0	0	0	-	0	0	0	0	-	0	0.01563	Grid
Tiloth	0	0	0	-	0	0	0	0	-	0	0	0	0	-	0	-	-	-	-	5.0	5	Plant S/D for MIV works
Dharasu	0	0	0	1.531	1.531	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1.531	Bushing oil leakage of T/F of Unit 4
Chilla	0.013	0	0	0	0.013	0.051	0.089	0.048	0.046	0.234	0	0	0	0	0	-	-	-	-	0.066	0.313	Grid, CT Burst of Feeder No 73, Excitation problem in Unit 4
Ramganga	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	-
Khatima	0.05	0	0	-	0.05	0.121	0	0	-	0.121	0	0	0	-	0	-	-	-	-	0.285	0.456	Grid, Bus bar problem, UPID closed Power Canal for repair works
Pathri	0	0	0.01	-	0.01	0.02330	0.02213	0.03560	-	0.08	0	0	0	-	0	0	0	0	-	0	0.09103	Grid, Shaft seal pressure low, OPU problem, T/F tripped
Mohd. Pur	0.0275	0.0026	0.007	-	0.0371	0.0059	0.01	0.0082	-	0.0241	0	0	0	-	0	0	0	0	-	0	0.06121	Grid, TGB problem, OPU problem
Galogi	0	0	0	0	0	0	0	0	0.008	0.008	0	0	0	0	0	0	0	0	0	0	0.008	Grid