

| Monthly Generation Loss (MU) | | | | | | | | | | | | | | | | | | | | | MIS | |
|--|------------------|-------|--------|--------|--------|------------------|---------|---------|--------|-----------|--------------------|-------|--------|--------|-------|------------------------|-------|--------|--------|--------------|------------|---|
| | | | | | | | | | | | | | | | | | | | | UJVN Limited | Date | |
| Generation Loss for the Month of February 2016 | | | | | | | | | | | | | | | | | | | | | | |
| Loss of Generation According to Water availability | | | | | | | | | | | | | | | | | | | | | | |
| Name of HEP | B/D of Equipment | | | | | System Condition | | | | | Flushing & Choking | | | | | Unusual & Other Reason | | | | | Total Loss | Remark |
| | Unit 1 | Unit2 | Unit 3 | Unit 4 | Total | Unit 1 | Unit2 | Unit 3 | Unit 4 | Total | Unit 1 | Unit2 | Unit 3 | Unit 4 | Total | Unit 1 | Unit2 | Unit 3 | Unit 4 | Total | | |
| Chibro | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | - |
| Khodri | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | - |
| Dhakrani | 0.004 | 0 | 0 | - | 0.004 | 0 | 0.00105 | 0 | - | 0.00105 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0.00505 | Magnetic valve operated in Unit 1, Grid disturbance |
| Dhalipur | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | - |
| Kulhal | 0 | 0 | 0 | - | 0 | 0.001 | 0.0007 | 0 | - | 0.00167 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0.00167 | Grid disturbance |
| Tiloth | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | - |
| Dharasu | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2.84 | 0 | 0 | 0 | 0 | 2.84 | 2.84 | S/D of plant due to Barrage protection Works |
| Chilla | 0 | 0 | 0.063 | 0 | 0.063 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.063 | Problem in intake gate of Unit 2 |
| Ramganga | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | - |
| Khatima | 0.06 | 0 | 0 | - | 0.06 | 0.031 | 0 | 0 | - | 0.031 | 0 | 0 | 0 | - | 0 | 0.042 | 0 | 0 | - | 0.042 | 0.133 | RMU Testing Works, Grid Disturbance, Excitation Problem in Unit 1 |
| Pathri | 0.01739 | 0.012 | 0.0062 | - | 0.0356 | 0.03503 | 0.03436 | 0.02548 | - | 0.0948700 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0.13049 | Cooling Water problem, Grid disturbance |
| Mohd. Pur | 0 | 0.002 | 0 | - | 0.002 | 0.0029 | 0.0013 | 0.003 | - | 0.0072 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0.0092 | OPU problem in Unit 2, Grid Disturbance |
| Galogi | 0.0003 | 0.003 | 0 | 0 | 0.0033 | 0.0005 | 0 | 0 | 0.0044 | 0.0049 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.006 | 0.006 | 0.0142 | Oil Leakage from OPU & Bearing of Unit 4 |