



Monthly Generation Loss (MU)

UJVN Limited

MIS

Date

Generation Loss for the Month of May 2016

Loss of Generation According to Water availability

Name of HEP	B/D of Equipment					System Condition					Flushing & Choking					Unusual & Other Reason					Total Loss	Remark	
	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total			
	Chibro	0	0	0	0	0	0.078	0.3864	0.2066	0	0.671	0	0	0	0	0	0	0	0	0			0
Khodri	0	0	0	0	0	0.0262	0.009	0.2127	0.0468	0.29469	0	0	0	0	0	0	0	0	0	0	0	0.29469	Grid
Dhakrani	0	0	0	-	0	0.0611	0.08002	0	-	0.14114	0	0	0	-	0	0	0	0	-	0	0	0.14114	Grid
Dhalipur	0.037	0	0	-	0.037	0.0614	0.0887	0.045	-	0.19509	0	0	0	-	0	-	-	-	-	-	0.081	0.31329	Grid
Kulhal	0	0	0	-	0	0.0653	0.0708	0.0234	-	0.159361	0	0	0	-	0	0	0	0	-	0	0	0.159361	Grid
Tiloth	0.068	16.353	0.028	-	16.449	0.636	1	0.396	-	2.032	0	0	0	-	0	0.286	0.286	0.22	-	0.792	19.273	Stator Fault Grid	
Dharasu	0	0	0	0	0	1.132	1.212	1.122	2.21	5.676	0	0	0	0	0	0	0	0	0	0	0	5.676	Grid
Chilla	0	0	0	0	0	0.505	0.494	0.486	0.097	1.582	0.322	0.322	0.199	0.552	1.395	-	-	-	-	0.066	3.043	Grid, F/C, CT burnt of Feeder 73	
Ramganga	0	0	0	-	0	0	0	0	-	0	0	0	0	-	0	0	0	0	0	0	0	0	-
Khatima	0.324	0.33	0	-	0.654	0.243	0.171	0	-	0.414	0	0	0	-	0	0	0	0	-	0	1.068	Numerical Relay Fail, Gov Fault,	
Pathri	0.0112	0.0075	0.0075	-	0.0262	0.17220	0.21346	0.23084	-	0.617	0.047	0.0308	0.0322	-	0.11	0	0	0	-	0	0.6427		
Mohd. Pur	0	0	0	-	0	0.1127	0.1049	0.11	-	0.3275	0.0115	0.0109	0.0227	-	0.0451	0	0	0	-	0	0.3275	Grid, F/C,	
Galogi	0	0	0	0	0	0	0.024	0	0.0158	0.0398	0	0	0	0	0	0	0	0	0	0	0.0398	Grid	