

Monthly Generation Loss (MU)

Name of HEP	Loss of Generation According to Water availability																					Total Loss	Remark
	B/D of Equipment					System Condition					Flushing & Choking					Unusual & Other Reason							
	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total			
Chibro	0.0	0.000	0.000	0.00	0.00	0.0	0.0	0.0	0.0	0.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	-	
Khodri	0.0	0.0	0.0	0.0	0.00	0.0	0.0	0.0	0.0	0.000	0.0	0.0	0.0	0.0	0.0	0	0	0.0	0.0	0	0	-	
Dhakrani	0.013	0.000	0.0	-	0.018	0.000	0.002	0.0	-	0.0023	0	0	0	-	0	0	0	0	-	0	0.02033	Abnormal sound, Grid, Differential Relay problem	
Dhalipur	0	0	0	-	0.00	0.000	0.004	0.000	-	0.0040	0.00	0	0	-	0.0	0	0	0	-	0	0.004	Grid	
Kulhal	0	0	0	-	0.0	0	0	0	-	0.000	0	0	0	-	0.0	0	0	0	-	0	0	-	
Tiloth	0	0	0	-	0.0	0	0	0	-	0.000	0	0	0	-	0	0	0	0	-	0	0	-	
Dharasu	0	0	0	0	0.000	0.000	0.000	0.000	0.0	0.000	0	0	0	0	0	0	0	0	0	0	0	-	
Chilla	0	0	0.1	0	0.066	0	0	0	0	0.000	0	0	0	0	0	0.0735	0.0735	0.0735	0.0735	0.294	0.36	Canal Closure, Oil Header problem	
Ramganga	0	0	0	-	0.0	0	0	0	-	0.0	0	0	0	-	0	0	0	0	-	0	0	-	
Khatima	0.008	0.009		-	0.017	0.048	0	0.058	-	0.106	0	0	0	-	0	0	0	0	-	0	0.123	Shaft Seal problem, Grid	
Pathri	0	0.005	0	-	0.005	0.012	0.062	0.072	0	0.146	0	0	0	-	0	0	0	0	-	0	0.15102	UGB problem, Grid	
Mohd. Pur	0	0	0	-	0.0000	0.0108	0.0108	0.0083	-	0.0299	0	0	0	-	0	0	0	0	-	0	0.0299	Grid	
Galogi	0	0	0	0	0.000	0.0019	0.0026	0	0.002	0.0065	0	0	0	0	0	0	0	0	0	0	0.0065	Grid	
																					0.69475		