

Monthly Generation Loss (MU)

Name of HEP	Loss of Generation According to Water availability																					Total Loss	Remark
	B/D of Equipment					System Condition					Flushing & Choking					Unusual & Other Reason							
	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total	Unit 1	Unit2	Unit 3	Unit 4	Total			
Chibro	0.0	0.000	0.000	0.04	0.04	0.0	0.0	0.0	0.0	0.000	0.3	0.9	0.9	0.2	2.3	0.7	3.1	1.6	0.3	5.6	7.90103	Rotor E/F of Khodri HEP, High Head Loss, F/C	
Khodri	0.0	0.0	0.0	0.0	0.03	0.0	0.0	0.0	0.0	0.000	0.4	0.2	0.1	0.3	1.0	0.808	0.0956	0.1	0.8	1.83868	2.90671	Rotor E/F, High Head Loss, F/C	
Dhakrani	0.0	0.000	0.1	-	0.1024	0.000	0.000	0.0	-	0.0000	0.1055	0.2039	0.137	-	0.4465	0.0379	0.0383	0.0403	-	0.11658	0.66542	F/C, F/P, T/F fault im Unit 3, Air tube pipe broken, Grid , Governor Pump problem	
Dhalipur	0.096	0	0	-	0.10	0.020	0.011	0.011	-	0.0420	0.34	0	0	-	0.8	0.053	0.053	0.057	-	0.163	1.07367	F/C, F/P, Lightnenning arresstor burst, Governor pump problem	
Kulhal	0	0	0	-	0.0	0.008	0	0.00482	-	0.013	0.2193	0.2912	0.3289	-	0.8	0.0227	0.0362	0.0352	-	0.09398	0.94607	F/P, F/C, Searching of dead body, Grid	
Tiloth	0.58	0.383	0	-	1.0	0	0	0	-	0.000	0	0	0	-	0	0	0	0	-	0	0.963	Rotor E/F, Unit 1 excitation cable burn, Grid, Gland seal work, Choking of water conducting system	
Dharasu	2.83	0.001	1.109	22.334	26.274	0.051	0.063	0.057	0.0	0.171	0	0	0	0	0	0	0	0	0	0	26.445	Stator E/F, Grid, TGB work in Unit 1, Overspeed problem	
Chilla	0	0.209	0.1	0	0.299	0.02613	0.018	0.02286	0.008	0.075	0.5585	0.6735	0.9265	1.5805	3.739	0	0	0	0	0	4.11299	F/C, Grid, Leakage from oil Header, Excitation problem, Servo tube	
Ramganga	0	0	0	-	0.0	0	0	0	-	0.0	0	0	0	-	0	0	0	0	-	0	0	-	
Khatima	0.021	0.036	0	-	0.057	0.00633	0.00633	0.00933	-	0.022	0	0.003	0.002	-	0.005	0.224	0.217	0.22	-	0.661	0.74499	Grid, Shear Pin broken, Canal Closure, Gen Bearing oil temp high	
Pathri	0	0.004	0	-	0.004	0.015	0.025	0.019	-	0.060	0	0	0	-	0	0	0	0	-	0	0.06357	Grid,	
Mohd. Pur	0.0001	0.0034	0.0024	-	0.006	0.0066	0.0034	0.0046	-	0.01	0.0039	0	0.0075	-	0.0114	0	0	0	-	0	0.03192	Grid, TGB temp high, F/C, MPR 1 relay trip	
Galogi	0	0	0	0	0.000	0.00125	0.00225	0	0.0048	0.0083	0	0	0	0.0027	0.0027	0	0	0	0	0	0.011	F/C, Grid,	
																					45.86537		